

Annual Drinking Water Quality Report for 2020

City of Geneva Water Treatment Plant

4163 Route 14 South, Geneva, NY

(Public Water Supply ID# 3401156)

INTRODUCTION

In compliance with state regulations, the City of Geneva WTP annually issues a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all state drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Kevin D. Munt at the City of Geneva Water Treatment Plant at (315) 789-5755. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled City Council meetings. The meetings are held on the first Wednesday of every month in the courtroom at the public safety building.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source is surface water pumped from Seneca Lake. During 2020, our system did not experience any restriction of our water source. The water is stored in a city reservoir, which can hold 5,000,000 gallons. The water is treated prior to distribution. We use slow sand and membrane microfiltration to reduce turbidity. We treat the water with chlorine for disinfection and phosphate for corrosion control. For promotion of strong teeth we add fluoride to our water.

The New York State Department of Health has completed a source water assessment. This assessment found an elevated susceptibility to contamination of this source of drinking water. The amount of agricultural lands in the assessment area results in elevated potential for phosphorus, disinfection by-product precursors, and pesticide contamination. While there are some facilities present, permitted discharges do not likely represent an important threat to source water quality based on their density in the assessment area. However, it appears that the total amount of wastewater discharged to surface water in this assessment area is high enough to further raise the potential for contamination (particularly for protozoa). There is also noteworthy contamination susceptibility associated with other discrete contaminant sources, and these facility types include landfills. A copy of the source water assessment is on file at the City of Geneva Water Plant.

FACTS AND FIGURES

Our water system serves approximately 12,762 city residents and about 2,000 town residents through 4,329 service connections. We maintain 82 miles of distribution piping, 755 valves and 534 hydrants in our system. The total water produced in 2020 was 612,772,000 gallons. The amount of water that we were able to meter this year was 571,471,167 gallons. This leaves an unaccounted total of 41,300,833 gallons with a loss of approximately 7.23%. Water loss can be attributed to things such as flushing of hydrants, water main breaks, washing and refilling of water plant filters, leaks, and fire department use. In 2020, the charge for a family of four using 13,000 gallons per quarter with a 5/8 meter was \$82.93, this equates to \$.98 cents per day. The total hardness of our water is 150 mgCaCO₃/liter or 8.7 grains per gallon.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers;
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get your monies worth and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- ◆ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes, if it moved, you have a leak.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, is more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Geneva District Office of the NYS Health Department at (315) 789-3030.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected Range	Unit	MCLG	Regulatory Limit MCL & AL	Likely Source of Contamination
Total Trihalomethanes (chloroform, bromoform, bromodichloromethane, dibromochloromethane) (**** Footnote)	NO	Quarterly 2020	57.44 (4quarter average.) (23-98.6) Low-High	ug/l	N/A	MCL=80 Annual Avg.	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter
Haloacetic acids (mono-, di-, and trichloroacetic acid, and mono-and di-bromoacetic acid) (**** Footnote)	NO	Quarterly 2020	22.68 (4 quarter average.) (15.9-35.40) Low-High	ug/l	N/A	MCL=60 Annual Avg.	By-product of drinking water chlorination
HABS	NO	Aug-Oct	>0.3	ug/l	N/A	1.6 µg/L for microcysts	Blue/Green algae formation at raw water intake.
Pfos/pfoa	NO	Oct & Dec	> 1.8	ng/l	N/A	Action level 10 ng/l	Possibly the Seneca Army Depot
nitrate	NO	2/2020	0.50	mg/l	10	MCL=10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
antimony	NO	2/2020	<0.0002	mg/l	50	MCL=50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
nickel	NO	2/2020	0.0007	mg/l	0.100	MCL=0.100	Metal alloys; electroplating; batteries; chemical production
fluoride	NO	Monthly 2020	0.96	mg/l	N/A	MCL=2.2	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
barium	NO	2/2020	0.0278	mg/l	2	MCL=2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Sodium (*** Footnote)	NO	2/2020	72.1	mg/l	N/A	***	Naturally occurring; road salt; water softeners; animal waste
Lead (* Footnote)	NO	Oct/2020	5.3 (0.0-17.5)	ug/l	N/A	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
copper	NO	Oct/2020	0.37 (0.022-0.814)	mg/l	1.3	AL=1.3	Corrosion of household plumbing deposits; leaching from wood preservatives
Turbidity (Distribution) (** Footnote)	NO	Apr/2020	2.15	NTU	<5.0 NTU	>5.0**	Highest sample measured from the field. Heavy use / water main breaks.
-Micro-Filters finished water -Sand Filters finished water	NO	2020	0.02- 0.28 0.02- 0.21	NTU	<1.0 NTU	95% of samples <1.0**	Samples taken at the Water Plant. Soil runoff
Radium 226 Radium 228 Gross Alpha	NO	Sept 2013	-0.0523+/-0.4 -1.819+/- .868 0.371+/- .496	pCi/L	0	MCL=5	Erosion of natural deposits.

*The level presented represents the 90th percentile of the 30 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead or copper values detected at your water system. In this case, thirty samples were collected at your water system and the 90th percentile value was the third highest value. The action level for Lead and Copper was not exceeded.

** Turbidity is a measure of the cloudiness of the water. We test it because it is a good indicator of the effectiveness of our filtration system. Our highest single daily turbidity in the distribution system was (2.15 NTU) and occurred on 4-1-2020. State regulations require that turbidity must always be below 5 NTU in the distribution system. The regulations require that 95% of the filters turbidity samples collected have measurements below 1.0 NTU. Throughout all of 2020 we had NO measurements exceeding 1.0 NTU.

***Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

****THM/HAA5 levels represent the highest locational running annual average calculated from data collected.

DEFINITIONS:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water; set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State. We are required to present the following information on lead in drinking water: If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. The City of Geneva Water Treatment Plant is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. **When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.** If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>. & <https://www.awwa.org/resources-tools/water-knowledge/lead/lead-communications.aspx>

The New York State Department of Health also offers Free Lead Testing at:

https://health.ny.gov/environmental/water/drinking/lead/free_lead_testing_pilot_program.htm

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2020, our system was in compliance with applicable state drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at a minimum concentration of 0.8 mg/l (parts per million). To ensure that the fluoride supplement in your water provides optimal dental protection, the State Department of Health requires that we monitor fluoride levels on a daily basis. During 2020 monitoring showed fluoride levels in your water were in the optimal range nearly 100% of the time. None of the monitoring results showed fluoride at levels that approach the 2.2 mg/l MCL for fluoride.

IN CLOSING

The City of Geneva has continued to invest in the Water Plant during 2020. Currently the Water Plant is considered one of the most advanced facilities in the region and is poised for success well into the future. Thank you for allowing us to continue to provide your family with quality drinking water this year. We ask that all our customers help us protect our water sources, which is the heart of our community. For questions regarding the content of the report, please contact Kevin D. Munt at the City of Geneva Water Treatment Plant at (315) 521-5687 or the NYSDOH at (315) 789-3030.